

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20240055  
Address: 1020 NW PRYOR RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Commercial</b>	Robb Popp	Ready for Temp CO	Wednesday, December 04, 2024

Corrective Action Required:

1	Misc	-Complete corrections for all other departments -Label RTUs-Use permanent labels -Label Hoods per LSFD -Seal penetrations at riser room-Missing at water line -Remove trash from rooftop
---	------	--

Comments: