

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20236327  
Address: 1113 SW CORINTHIAN LN, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Shawn Hoffman	Failed	Wednesday, December 04, 2024

Corrective Action Required:

- |   |      |  |
|---|------|--|
| 1 | Misc |  |
|---|------|--|
- final grading and sod
  - Seal top of electrical meter can and A/C disconnect
  - Label non- GFCI outlet in garage
  - Handrail at garage stairs at 40" ( lower to 34-38")
  - Provide back flow prevention at spigot basement by main shut off

**Comments:**