## CITY OF LEE'S SUMMIT

**Development Services Department** 220 SE Green Street Lee's Summit, MO 64063 FAX (816) 969-1201 (816) 969-1200

## **Temporary Certificate of Occupancy**

Permit #: PRRES20240626

**Address:** 3212 SW ARBOR SOUND DR, LEES SUMMIT, MO 64082

**Inspected On:** Wednesday, December 04, 2024

**Inspected By: Development Center Expiration Date:** 9/14/2024 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Outcome: Inspection: Inspector: Date:

**Occupancy Inspection - Codes** Mitchell Schwarz Ready for Temp CO Thursday, August 15, 2024

Residential

Corrective Action Required:

-Final grade and sod Misc

-Splash blocks and sump pump discharge to extend 36" from foundation

-uncover covered water meter -obtain issued irrigation permit

**Comments:**