

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSITE20233869
Address: 130 NW MURRAY RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Sidewalk Inspection	John Jackson	Passed	Thursday, December 05, 2024

Informational:
1 Misc 08/07/24 Wednesday JMJ (Quality Custom Construction)
Contractor poured sidewalk to the Northwest side of building, note: rebar was installed with no chairs pre-inspection was not requested by contractor.

Comments: