

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20235733  
Address: 209 SE GREEN ST, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Underground Electrical Inspection - Commercial</b>	Robb Popp	Partial	Thursday, December 05, 2024

Informational:

1	Misc	-Conduit from mech room 118 to west exterior -Communication conduit from 118 to line 5 (108 mechanical) -Conduit for (4) receptacles at SW corner of City Hall -Conduit from SE sidewalk to NE corner and East to courtyard stairs and clocktower -Christmas tree run at SE corner of city hall to quaside box roughly 15' from west side of building -Ground ring with (3) ground rods at transformer location for service disconnect
---	------	---

Informational:

2	Miscellaneous Correction	Electrical street lighting conduit west side of Johnson street south of Cooper This is a partial pass only. Okay to cover
---	-----------------------------	--

**Comments:**