

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20245653
Address: 1028 SW ARMIE ST, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Shawn Hoffman	Failed	Thursday, December 05, 2024

Corrective Action Required:

1	Misc	- move gas pipe bonding clamp to unfinished space or provide access panel in bathroom - Fire block top plate at both steel columns near stairs - Fire block gap at top plate at double wall hallway - Provide high and low combustion air ventilation or run furnace intake to outside
---	------	---

Comments: