

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20242763  
Address: 3713 SW KNOXVILLE CT, LEES SUMMIT, MO 640823711 SW KNOXVILLE CT, LEES SUMMIT, MO  
64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Kyle Beard	Failed	Thursday, December 05, 2024

Corrective Action Required:

1	Miscellaneous Correction	Exterior garage PFH sheeting failed. Fasteners do not attach to both top plates
---	--------------------------	---

This was a partial inspection for exterior portal sheeting only

**Comments:**