

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20221553  
Address: 1616 SW 27TH ST, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Erosion Control</b>	Dustin Agcopra	Failed	Thursday, December 05, 2024

Corrective Action Required:

1	Misc	- REMOVE TRASH AND DEBRIS FROM LOT
---	------	------------------------------------

Corrective Action Required:

2	DCM3 ESC REQUIRED 2 DAY	12-5-24 Dustin A, EROSION CONTROL REQUIRED. EROSION CONTROL SHALL BE IN COMPLIANCE WITHIN TWO BUSINESS DAYS. Silt fence down
---	----------------------------	--

**Comments:**