# CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

# **DEVSERVICES.CITYOFLS.NET**

# **Inspection Summary**

Permit #: PRRES20242467

Address: 3229 SW ARBOR TREE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

Occupancy Inspection - Codes Mitchell Schwarz Failed Thursday, December

Residential 05, 2024

## Corrective Action Required:

2 Misc

-final grade and sod

-splash blocks and sump pump discharge to extend 36" from foundation

-address water meter pit missing lid

-ensure water meter pit top is flush with grade and meter top to well lid ring

is 14"-18"

-outlets under kitchen sing to be gfci protected -repair hole in drywall near stairs in garage

### Comments: