

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20226232
Address: 120 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	Robb Popp	Failed	Thursday, December 05, 2024

Corrective Action Required:

1 FIRST FLOOR *****AREAS APPROVED TO COVER:
-Entry canopy ok to cover
Additon complete except as noted
-Clean room at existing tie in 1E 169. Address penetrations and incomplete rated assembly

**Existing side:
1E-314-seal penetrations
300C-seal penetrations and label firewall
1E-315-Label firewall
1E-313-seal penetrations and label firewall
02-1E153 & Materials Management 02-1E152-Label firewall, seal all penetrations, remove all penetrations must comply with UL 1479 or ASTM E814

Corrective Action Required:

2 SECOND FLOOR Above-ceiling OK below:
**Addition Complete except at existing south stair: label fire wall

Corrective Action Required:

3 THIRD FLOOR **Addition complete

Comments: