

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20242857

Address: 1420 SW WINTHROP TER, LEES SUMMIT, MO 64081
1418 SW WINTHROP TER, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	Kyle Beard	Failed	Thursday, December 05, 2024

Corrective Action Required:

1	Misc	ATTIC SPACE AND RIM BOARDSCREW PATTERN BOTH SIDES APPROVED ONLY (ready for tape)
---	------	---

Corrective Action Required:

3	Miscellaneous Correction	1418 - The shower area needs the outside Sheetrock edges secured to backing every 8 inches on center
---	-----------------------------	--

1420 passed rated assembly inspection

Comments: