

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20235203  
Address: 2991 SE SHENANDOAH PKWY, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Footing Inspection - Commercial</b>	Khanh Nguyen	Partial	Thursday, December 05, 2024

Corrective Action Required:

1	Misc	Lower level foundation: -Exterior footing -Storm shelter, column pads, columns for storm shelter -Elevator pad and pit wall -Storm shelter elevated slab
---	------	--

Comments: