

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20242122
Address: 369 NW PATCH CT, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Shawn Hoffman	Failed	Thursday, December 05, 2024

Corrective Action Required:

2	Misc	- Nail to code sheeting of CS-PF around main floor sliding door
		- Secure CSST gas line within 12" of appliance at main floor fireplace
		- Provide security blocking at back door basement

Comments: