

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20242467
Address: 3229 SW ARBOR TREE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mitchell Schwarz	Failed	Friday, December 06, 2024

Corrective Action Required:

1	Misc	-final grade and sod -splash blocks and sump pump discharge to extend 36" from foundation -address water meter pit missing lid -ensure water meter pit top is flush with grade and meter top to well lid ring is 14"-18" -outlets under kitchen sink to be gfci protected
---	------	---

Comments: