

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20242565
Address: 1612 SW BUCKTHORN ST, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mitchell Schwarz	Failed	Friday, December 06, 2024

Corrective Action Required:

1 Misc

- sod
- splash blocks and sump pump discharge to extend 36" from foundation
- will check water meter at time of sod. Ensure 14"-18" from top of meter to well ring lid
- outlets in garage to be gfci protected or single pull receptacle and labeled
- address deck post to beam connections

Comments: