

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20242469  
Address: 1609 SW BUCKTHORN ST, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Mitchell Schwarz	Failed	Friday, December 06, 2024

Corrective Action Required:

2	Misc	-address pending sidewalk inspection -provide as graded plot plan -uncover covered water meter pit -garage door to be self closing and latching -water hammer device for dishwasher
---	------	---

**Comments:**