

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20241110  
Address: 2078 NW OBRIEN RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Plot Plan Inspection</b>	Robb Popp	Failed	Friday, December 06, 2024

Corrective Action Required:

1	Misc	-As graded plot plan required -Lower water meter to riser to grade. Maintain 14"-18" to meter -Man Hole in backyard covered -Retaining wall not shown on plans
---	------	---

**Comments:**