

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20243784
Address: 1539 SW ARBOR VALLEY DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Shawn Hoffman	Failed	Friday, December 06, 2024

Corrective Action Required:

3	Misc	- Anchor bolts to be in middle third of sil plate at garage portal frame and return wall - Address 5 consecutive studs overboard on bearing wall at primary bathroom vanity R602.6.1
---	------	---

Comments: