

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20242723  
Address: 1054 SW FIORD DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Driveway Inspection</b>	Dustin Agcopra	Partial	Friday, December 06, 2024

Informational:

1	Misc	12-6-24 Dustin A, dw is formed and compacted. Gravel depth is insufficient. Will need dug out . Chris is going to call and let me know when it's corrected
		12-6-25 Dustin A, approach has been corrected . Approved to pour

**Comments:**