CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20243024

Address: 3217 SW SADDLEBRED TER, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Inspector: Outcome: Date:

All Rough Inspection - Mitchell Schwarz Not Ready Friday, December 06,

Residential 2024

Corrective Action Required:

1 Misc Re establish premises identification

Scheduled gas and electric with all rough on re inspection

NOT A COMPLETE LIST HOUSE NOT READY FOR INSPECTION, COMPLETE LIST

BEFORE CALLING FOR RE INSPECTION

- -garage portal frame nailing covered without inspection
- -anchor bolts to be within 12" of plate breaks in garage
- -missing PFH anchor bolt washers
- -fireblock garage rear wall into fire down above laundry
- -bring electrical to furred out wall into fire garage at laundry
- -provide hangers for joist above owners entry closet
- -connect bath vent at powder room
- -uncover steel colum in garage for inspection
- -nail plate under header at pfh to header 3" O.C per design
- -nail all exterior sheathing to plans 6" OC on edges and 12" OC in field.

Comments: