

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816) 969-1200 FAX (816) 969-1201

# Temporary Certificate of Occupancy

---

**Permit #:** PRRES20242565  
**Address:** 1612 SW BUCKTHORN ST, LEES SUMMIT, MO 64082  
**Inspected On:** Monday, December 09, 2024  
**Inspected By:** Development Center  
**Expiration Date:**

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Mitchell Schwarz	Ready for Temp CO	Monday, December 09, 2024
Corrective Action Required:			
1 Misc	-sod		
	-splash blocks and sump pump discharge to extend 36" from foundation		
	-will check water meter at time of sod. Ensure 14"-18" from top of meter to well ring lid		

**Comments:**