

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20244348
Address: 2317 SW MORRIS DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control	Dustin Agcopra	Failed	Monday, December 09, 2024

Corrective Action Required:

1	DCM3 ESC REQUIRED 2 DAY	10-14-24 Dustin A, EROSION CONTROL REQUIRED. EROSION CONTROL SHALL BE IN COMPLIANCE WITHIN TWO BUSINESS DAYS. Silt fence down 10-17-24 Dustin A, corrected
---	----------------------------	---------------------------------------------------------------------------------------------------------------------------------------------------------------

Corrective Action Required:

2	DCM3 ESC REQUIRED 2 DAY	10-30-24 Dustin A, silt fence down. EROSION CONTROL REQUIRED. EROSION CONTROL SHALL BE IN COMPLIANCE WITHIN TWO BUSINESS DAYS.
---	----------------------------	--------------------------------------------------------------------------------------------------------------------------------

11-4-24 Dustin A, silt fence is still down,
11-4-24 Dustin A, Silt fence repaired

Corrective Action Required:

3	DCM3 ESC REQUIRED 2 DAY	12-9-24 Dustin A, Silt fence is down in spots. Needs repaired. EROSION CONTROL REQUIRED. EROSION CONTROL SHALL BE IN COMPLIANCE WITHIN TWO BUSINESS DAYS.
---	----------------------------	-----------------------------------------------------------------------------------------------------------------------------------------------------------

Comments: