



CITY OF LEE'S SUMMIT  
CODES ADMINISTRATION  
220 SE GREEN ST.  
P.O.BOX 1600

PHONE:  
816-969-1200

FAX:  
816-969-1201

## Inspection Summary

---

Permit #: PRCOM20115441, Building Permit - Commercial  
Address: 910 NW BLUE PKWY, Unit:P, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>In-wall Inspection</b>	John Borns	Partial	Tuesday, November 08, 2011

Partial Correction  
1 MISC

OK TO HANG REMAINING GWB AT SALES AREA WALLS;  
COLUMN WRAPS, AND SOFFITS -- CONTINGENT ON  
SOFFIT/BULKHEAD TENSION SUPPORT STUDS BEING SCREWED  
BOTH FLANGES AT UPPER ENDS.

**Comments:**