

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20243302
Address: 1808 SW HIGHTOWN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control	Shawn Hoffman	Failed	Monday, December 09, 2024

Corrective Action Required:	
2 DCM2 ESC	DEFICIENT EROSION CONTROL INSTALLATION. NO FURTHER INSPECTIONS
DEFICIENT	UNTIL ADEQUATE EROSION CONTROL PROVIDED.
INSTALLATION	

Comments: