

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20243667  
Address: 2610 SW TRACKER LN, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection:                | Inspector:     | Outcome: | Date:                     |
|----------------------------|----------------|----------|---------------------------|
| <b>Driveway Inspection</b> | Dustin Agcopra | Failed   | Monday, December 09, 2024 |

Corrective Action Required:

|   |      |                                                                                                                         |
|---|------|-------------------------------------------------------------------------------------------------------------------------|
| 1 | Misc | 12-9-24 Dustin A, Dw was called in but gravel was to shallow. They are going to correct and i will be back my tomorrow. |
|---|------|-------------------------------------------------------------------------------------------------------------------------|

**Comments:**