

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20244953
Address: 1909 SW HIGHTOWN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Shawn Hoffman	Failed	Tuesday, December 10, 2024

Corrective Action Required:

1	Miscellaneous Correction	Provide information on black tie down screws used in the garage
		Steel Ibeam in basement along the west wall does not bear on 3 inches of concrete in the pocket
		2x10 in the basement above electrical panel has
		Ibeam in basement does not bear 3 inches in the concrete pocket at the NW corner together
		Gas lines (no presure)

Comments: