

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20241110
Address: 2078 NW OBRIEN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Robb Popp	Ready for Temp CO	Tuesday, December 10, 2024

Corrective Action Required:

1	Misc	-As graded plot plan required -Man Hole in backyard covered -Retaining wall not shown on plans -Complete final grade, sod beyond fence -Install A35 both sides of rafters at pergola
---	------	--

Comments: