

RELEASE FOR CONSTRUCTION
AS NOTED FOR PLAN REVIEW
DEVELOPMENT SERVICES
LEE'S SUMMIT, MISSOURI
12/10/2024

NOTE: SUMP PIT SHALL BE
EQUIPPED WITH A PUMP
AND RECEPTACLE. IN
UNFINISHED PORTIONS OF
BASEMENT, RECEPTACLES
SHALL HAVE GFI PROTECTION

