

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20245263
Address: 2626 SW FIREFLY LN, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mitchell Schwarz	Failed	Tuesday, December 10, 2024

Corrective Action Required:
2 Misc

- Address rear cspf wall not framing to design. incorrect header size, header does not extend to wall corners
- provide smoke/co outside immediate vicinity of bedrooms
- identify ufer ground connection at both ends

Comments: