



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20114124, Building Permit - Commercial
Address: 1704 NW CHIPMAN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Final Building Inspection - Commercial	John Borns	Passed	Wednesday, November 09, 2011

Occupancy Inspection - Fire	Joe Dir	Passed	Wednesday, November 09, 2011
------------------------------------	---------	--------	------------------------------

Corrective Action Required
1 MISC

- (1) install exit signage and emergency lighting as per plans
- (2) install additional exit signage for the sales floor area by the NE exit with directional arrow
- (3) install additional exit signage for the back work area with directional arrow to direct egress to the NE exit.
- (4) test all exit and emergency lighting throughout store for battery power operation.

Corrective Action Required
2 MISC

All previous violations corrected

Comments: NO REMAINING ISSUES. CLOSE PERMIT.