

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20233629
Address: 3215 SW ENOCH ST, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control	Dustin Agcopra	Failed	Tuesday, December 10, 2024

Informational:

1	DCM3 ESC REQUIRED 2 DAY	10-14-24 Dustin A, Stopped and talked to builder about erosion control. He is sodding this week,
---	----------------------------	--

Corrective Action Required:

2	DCM3 ESC REQUIRED 2 DAY	12-10-24 Dustin A, Silt fence down in rear lot, debris on public sidewalk EROSION CONTROL REQUIRED. EROSION CONTROL SHALL BE IN COMPLIANCE WITHIN TWO BUSINESS DAYS.
---	----------------------------	--

Comments: