

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20240980
Address: 1550 SE HAMBLER RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Pavement-Aggregate Base	Bobby Richest	Passed	Tuesday, December 10, 2024

Informational:

1	Misc	12-5-24 BR Contractor installed geogrid with 6" MoDot type 1 aggregate base on 30% of excavated widening lane
		12-6-24 BR Contractor installed geogrid with 6" MoDot type 1 aggregate base on 100% of excavated widening lane with compacted ready for asphalt base.

Comments: