

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRSUBD20240980  
Address: 1550 SE HAMBLER RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Pavement-Aggregate Base</b>	Bobby Richest	Partial	Monday, December 09, 2024

Informational:

1	Misc	12-5-24 BR Contractor installed geogrid with 6" MoDot type 1 aggregate base on 30% of excavated widening lane
		12-6-24 BR Contractor installed geogrid with 6" MoDot type 1 aggregate base on 100% of excavated widening lane with compacted ready for asphalt base.

**Comments:**