

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20241493
Address: 2120 NW OBRIEN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|-------------------------------------------|------------|----------|---------------------------------|
| All Rough Inspection - Residential | Robb Popp | Failed | Wednesday, December 11, 2024 |

Corrective Action Required:

| | | |
|---|--------------------------|-----------------------------------------------------------------------------------------------------|
| 1 | Miscellaneous Correction | Garage PFH sheeting break should be located within 24 inches of the middle 1/3 of garage portal leg |
|---|--------------------------|-----------------------------------------------------------------------------------------------------|

This inspection was for a garage PFH only

Corrective Action Required:

| | | |
|---|------|---------------------------------------------------------------------------------|
| 2 | Misc | 12/11/24 -Inspection denied. No address posted. -Clean debris from street |
|---|------|---------------------------------------------------------------------------------|

Comments: