

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRSUBD20232901  
Address: 2840 SE BLUE PKWY, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Sanitary Sewer - Vacuum</b>	Bobby Richest	Partial	Thursday, December 12, 2024

Informational:  
1 Misc 12-11-24 BR Contractor preformed vacuum test on MH A-5, MH A-4, MH C-1, MH C-2, MH G-1, MH C-3 pass.

**Comments:**