

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20245645
Address: 2082 NW OBRIEN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underslab Plumbing Inspection - Residential	Mark Harding	Failed	Thursday, December 12, 2024

Corrective Action Required:

1	Misc	POST ADDRESS - no further inspections -no venting within 8ft of 3 floor drains at the front of the basement. -negative fall at rear plumbing. fill in basemnt and support plumbing to the floor at the over dig. - connect interior drain tile. install approved erosion control in the rear
---	------	--

Comments: