

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20242369  
Address: 1617 SW ARBORWAY TER, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Mitchell Schwarz	Failed	Thursday, December 12, 2024

Corrective Action Required:

1	Misc	-address to be properly illuminated -address pending driveway inspection -final grade and sod -bring water meter pit to grade (ensure 14"-18" from top of meter to well lid ring) -guard rail at front stoop where required -identify sewer tracer wire
---	------	--

Comments: