

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

Temporary Certificate of Occupancy

Permit #: PRRES20243302
Address: 1808 SW HIGHTOWN DR, LEES SUMMIT, MO 64082
Inspected On: Thursday, December 12, 2024
Inspected By: Development Center
Expiration Date:

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mitchell Schwarz	Ready for Temp CO	Thursday, December 12, 2024

Corrective Action Required:

- | | | |
|---|------|--|
| 1 | Misc | - Pay all fees
- Address pending sidewalk inspection
- Obtain an irrigation permit and submit a back flow certificate
- Raise water meter pit to grade with meter height at 14-18" from lid |
|---|------|--|

Comments: