

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20244575
Address: 2721 SW 12TH ST, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|---|--------------|-----------|-----------------------------|
| All Rough Inspection - Residential | Mark Harding | Not Ready | Thursday, December 12, 2024 |

Corrective Action Required:

| | | |
|---|------|--|
| 1 | Misc | - Garage poral ok - Porch roof missing hold down devices on trusses |
|---|------|--|

Corrective Action Required:

| | | |
|---|------|--|
| 2 | Misc | -clean all gravel out of the street . -No plans on site -no plate straps, missing plumbing support, missing fire blocking throughout, no inspection |
|---|------|--|

Comments: