

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20245263  
Address: 2626 SW FIREFLY LN, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Mitchell Schwarz	Failed	Thursday, December 12, 2024

Corrective Action Required:

1	Misc	-Address rear cspf missing plate under header per design and nailed -provide smoke/co outside immediate vicinity of bedrooms (main floor front bedroom needs to be 3' away from bathroom.
---	------	--

**Comments:**