

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20246336
Address: 3202 SW ENOCH ST, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mitchell Schwarz	Failed	Thursday, December 12, 2024

Corrective Action Required:

1 Misc

- provide city stamped plans onsite for re inspection
- fireblock all walls to ceiling spaces and furr downs
- fireblock walls horizontally every 10' from floor to ceiling
- provide ventilation for bathroom
- support furr down ceiling joists to floor joists above.

Comments: