

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

Temporary Certificate of Occupancy

Permit #: PRRES20242647
Address: 3224 SW ARBORIDGE CIR, LEES SUMMIT, MO 64082
Inspected On: Thursday, December 12, 2024
Inspected By: Development Center
Expiration Date:

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mitchell Schwarz	Ready for Temp CO	Thursday, December 12, 2024
Corrective Action Required:			
1 Misc	-final grade and sod -install gutters -splash blocks and sump pump discharge to extend 36" from foundation		

Comments: