

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

Temporary Certificate of Occupancy

Permit #: PRRES20242155
Address: 1632 SW BUCKTHORN ST, LEES SUMMIT, MO 64082
Inspected On: Thursday, December 12, 2024
Inspected By: Development Center
Expiration Date: 12/19/2024 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Kyle Beard	Ready for Temp CO	Tuesday, November 19, 2024

Corrective Action Required:

- | | | |
|---|--------------------------|--|
| 1 | Miscellaneous Correction | -Sidewalk final is not complete
-Sod, splash pads and sump pump extension need to be completed
-Seal all exterior penetrations
-Plot plan needs to pass |
|---|--------------------------|--|

Passed for TCO only

Comments: