

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20242465
Address: 2759 SW 12TH TER, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|------------------------|---------------|----------|---------------------------|
| Erosion Control | Shawn Hoffman | Failed | Friday, December 13, 2024 |

Corrective Action Required:

| | | |
|---|---------------------------------------|--|
| 1 | DCM2 ESC DEFICIENT INSTALLATION | DEFICIENT EROSION CONTROL INSTALLATION. NO FURTHER INSPECTIONS UNTIL ADEQUATE EROSION CONTROL PROVIDED. - REMOVE TRASH AND DEBRIS FROM LOT - REPAIR SILT FENCE |
|---|---------------------------------------|--|

Corrective Action Required:

| | | |
|---|----------------------------|--|
| 2 | DCM3 ESC REQUIRED 2 DAY | EROSION CONTROL REQUIRED. EROSION CONTROL SHALL BE IN COMPLIANCE WITHIN TWO BUSINESS DAYS. - REPAIR SILT FENCE - REMOVE TRASH AND DEBRIS FROM STREET |
|---|----------------------------|--|

Comments: