

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20242156
Address: 2760 SW 11TH ST, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Driveway Inspection	Dustin Agcopra	Passed	Friday, December 13, 2024

Informational:

1 Misc

12-6-24 Dustin A, dw is formed and compacted .Gravel is less then 2 inch in some areas needs to be dug out more. FAIL
12-6-24 Dustin A, dw has been corrected. Approved to pour
12-13-24 Dustin A, DW has been poured to city specs. forms have been pulled. Passed

Comments: