

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRSUBD20231337

Address: 940 NE COLBERN RD, LEES SUMMIT, MO 64064900 NE COLBERN RD, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Erosion Sediment Control (ESC) Inspection</b>	Nick Scott	Partial	Friday, December 13, 2024

Informational:

1 Misc

Colbern road investments

12-18-23 NS Site Visited and no erosion control issues

12-22-23 NS Site Visited and no erosion control issues

1-3-24 NS Site Visited and no erosion control issues

1-23-24 NS Site Visited and no erosion control issues

3-29-24 NS Site Visited and no erosion control issues

4-18-24 NS Site Visited and no erosion control issues

6-28-24 NS Site Visited and no erosion control issues

7-25-24 NS Site Visited and no erosion control issues

8-8-24 NS Site Visited and no erosion issues

8-22-24 NS Site Visited and no erosion issues

9-30-24 NS Site Visited and no erosion control issues

10-14-24 NS Silt fence needs to be put back up and repaired around job site with grass seed put down with gutter buddies in every storm inlet.

10-31-24 NS Site Visited and no work has been done since last inspection.

11-6-24 NS Site Visited and still no erosion control has been fixed from. I will contact the developer

11-13-24 NS Site Visited and still no erosion control has been fixed

12-13-24 NS Site Visited and still no erosion control issues

**Comments:**