

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20224156
Address: 512 NE PROMISED VIEW DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Khanh Nguyen	Failed	Friday, December 13, 2024

Corrective Action Required:

1	Misc	-Fb half bathroom wall from roof -Protect plumbing at pantry wall -Fb sport closet both vertical and at ceiling level; fb elevator wall from floor space -Draft stop ceiling space into equal spaces of no more than 1000 square ft -Gas piping union fitting cannot be in concealed space **Make this accessible -Fb basement guest bedroom&bathroom wall space from ceiling space -Complete installing feeder to detached garage panel -Fb detached garage wall vertically with 3/4" sheathing or other approved material
---	------	--

**OK TO INSULATE

Comments: