

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20240700

Address: 207 NW ORCHARD CT, LEES SUMMIT, MO 64063 205 NW ORCHARD CT, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Robb Popp	Failed	Friday, December 13, 2024

Corrective Action Required:

1 Misc

Unit 205:

- DWV outside of shower wall-NOT ADDRESSED
- Complete DWV at grinder pump (Can verify when complete)
- \*OK to insulate, do not cover inspection items

Unit 207:

- Complete DWV at grinder pump (Can verify when complete)

**Comments:**