

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20242328  
Address: 3505 SE CORBIN DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Khanh Nguyen	Failed	Monday, December 16, 2024

Corrective Action Required:

1	Misc	- Missing nails in 3 stud shoes at hallway bathroom. **Not done
---	------	---

\*\*OK TO INSULATE

\*\*Make sure to install flashing above window trims

**Comments:**