

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20242763

Address: 3713 SW KNOXVILLE CT, LEES SUMMIT, MO 64082
3711 SW KNOXVILLE CT, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Robb Popp	Failed	Monday, December 16, 2024

Corrective Action Required:

1	Miscellaneous Correction	Exterior garage PFH sheeting failed. Fasteners do not attach to both top plates
---	--------------------------	---

This was a partial inspection for exterior portal sheeting only

Corrective Action Required:

2	Misc	12/16/24 -Inspection denied. Provide effective erosion control at front, side and back of lot. Clean debris from streets and protect storm inlets
---	------	--

Comments: